



**California Department of Forestry and Fire Protection
Butte County Fire Department
Fire Prevention Bureau**

176 Nelson Avenue, Oroville CA 95965
(530) 538-7888 Office, (530) 538-2105 Fax

LRA Building Permit # _____ - _____

Under authority of the California Fire Code (CFC), the following items are required by CAL FIRE/Butte County Fire Department for all development located within the Local Responsibility Areas of Butte County and are required as part of this permit. These requirements are minimums and may be superseded by Butte County local regulations exceeding these standards.

2007 California Fire Code

LPG Tanks

3807.3, LPG Tank Clearance of Combustibles

Weeds, grass, brush, trash and other combustible materials shall be kept a minimum of 10 feet from LP-gas tanks or Containers.

3807.4 Protecting LPG containers from vehicles

Where exposed to vehicular damage due to proximity to alleys, driveways or parking areas, LP-gas containers, regulators and piping shall be protected in accordance with Section 312.

Fire Department Fees

_____ Fire department fees are collected by the Butte County Development Services Department at the time of application for your building permit. You are assessed two fees (site plan review and pre-inspection). Additional fees will be assessed when the fire department inspector is required to perform additional inspections of your property, those additional fees must be paid to Development Services, 7 County Center Drive in Oroville.

All of the Fire Safe Requirements are posted on the Butte County Fire Department website at
<http://buttefire.org/Fireprevention/protplan/protplan.html>

Check the status of your permit online at
http://dspermits.buttecounty.net/etrakit/Permit_Search.asp

Need a fire department inspection? Call our inspection line.
(530) 538-6226